



My Circuit Dome

Designed by Michael Anastassiades, 2023

40W - 2268lm - 3000K - CRI> 90 - Beam° 110

Suspended luminaire for installation in the My Circuit system. Diffused downlight emission. Adjustable suspension height. Casambi version for wireless control.

Are you a professional and your project needs consulting and support?


BOOK AN APPOINTMENT

Main specifications

Mounting	Track	
Environments	Indoor dry location	
Light source type	LED	
Light sources included	Yes	
LED type	Top LED	
Number of lamps	5 1	
Power (W)	40	
Source flux (lm)	3700	
Lumen Output (lm)	2268	
Efficacy (lm/W)	58	

Physical

Colour	White
Orientation	Fixed
Length (mm)	500
Cord colour	White
Cord length (mm)	Max 3000
Net weight (kg)	0.2
IP internal	20



Download

Mounting instructions

业 PDF

Photometric Files

LDT / IES

₹ ZIP

Technical Drawings

2D <u>♣</u> ZIP 3D <u>♣</u> ZIP









Ecodesign and Energy Labelling





Non-replaceable light source



Replaceable control gear by a professional

https://professional.flos.com/en/global/product/my-circuit-dome-05.2996.c5/

05.2996.C5

Schematic light drawing



Beam	Beam Angle:	
h(m)	E(lx)	D(n
1	821	2.8
2	205	5.6
3	91	8.5
4	51	11.3

33 14.19

5

Luminous flux luminaire 2296 lm


Photometric

Lighting type	Direct
Light distribution	Symmetric
CCT (K)	3000
CRI>	90
McAdam steps (SDCM)	3
Rf fidelity index	91
Rg gamut index	92
LED Life / Failure Ratio	L70B50 > 65.000h (Tc=85°C)
Beam angle C0-180 (°)	110
Beam angle C90-270 (°)	110

Electrical

Insulation class	III
Forward voltage (V)	48
Power supply	Remote excluded
Dimmable	Yes
Power supply type	Dimmable Casambi
Dimming interface	Remote Dimmable (Dimmer Not Included)

Accessories & Power Supply



OPTIONAL
Control interface

Electrical

08.0824.14

Dimming Interface 1-10V to CASAMBI